

Certificate Number: 8832

# CERTIFICATE OF SUITABILITY

**THIS is to certify that articles of the same type as the article specified below and variations so specified are accepted by the OFFICE OF FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS3000 subject to the conditions stated.**

**Article:**

**Heating Cable**

(Single-core heating conductor with seven strands, teflon insulation, earth shielding of tinned copper braid, second insulation of PVC, return wire of tinned copper braid and outer sheath of PVC and having a maximum surface temperature of 80°C)

**Trade Name: 'dansk varmekabel'**

**230V., a.c., 240-3000W. Max.**

**Identification: DVT 20**

**Examined for compliance with: IEC 60800 : 1992**

**Issued to: Dansk Varmekabel A/S**

**Nominated Marking: CS8832N**

**Conditions:**

- 1. This certificate will be withdrawn automatically if an article of this type is declared pursuant to the Electricity (Consumer Safety) Act, 2004.**
- 2. This certificate is issued subject to the article and accepted variations thereof being maintained at the standard of the article examined at the time of acceptance.**

**Approved: 31 July 2007**

**This approval expires 31 July 2012 unless suspended, cancelled, renewed or extended.**



**for Commissioner for Fair Trading**